

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 1317

Dated: 21/04/2025

It is certified that an inspection team headed by **Mr. V. P. Gawali, Chief Bacteriologist** (Name of Officers with designation) from **District Public Health Laboratory, Yavatmal** (PHED)

Inspected the **Scholars International School, Mardi Road, Maregaon** (Name & address of the school) on **15/04/2025** (date of inspection) and on the basis of Water Test Report (Attached) bearing

no. 1295, 1293 dated **17/04/2025** Of **District Public Health Laboratory,**

Yavatmal (PHED Lab) certified that the **Scholars International School, Maregaon** (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/U.T. Govt.

This certificate is valid till 6 months

Signature with Seal


Chief Bacteriologist
Dist. Public Health Laboratory
Yavatmal

Name

: V. P. Gawali

Designation

: Chief Bacteriologist

Name & Address of the Office / Department :

**District Public Health Laboratory,
Vasant Rao Naik Government Medical College &
Hospital, Yavatmal 445301**

To

Principal,

Scholars International School

Mardi Road, Maregaon

District- Yavatmal

Maharashtra


Principal
Scholars International School
Maregaon


Manager
Scholars International School
Maregaon

Note : The certificate is to be issued by authorized officer / PHED Lab / local bodies

District Public Health Laboratory, Yavatmal.

E-mail ID: dphlyvr@gmail.com

Phone :07232-242946

REPORT ON CHEMICAL EXAMINATION OF WATER FOR DRINKING PURPOSES

Dt. of Collection:- 15/4/2025 Dt. of Receipt:- 15/4/2025 -Dt. of Exam:- 15/4/2025 onwards
(All the Analytical Results are in mgs. / liter except pH & Turbidity)

SR.NO	TEST PARAMETER	① RO Filter, Scholar's int. School.	BIS Specifications 10500 : 2012(Edn.2.2) Normal Values	
			Desirable Limits	Permissible Limits
1	Physical Appearance	clear	--	--
2	Odour	Odourless	Unobjectionable	--
3	Turbidity (N.T.U.)	0.1	1	5
4	P ^H Value	7.0	6.5 to 8.5	No Relaxation
5	Fluoride (as F)	0	1	1.5
6	Nitrates (as NO ₃)	0	45	No Relaxation
7	Total Dissolved Solids	96	500	2000
8	Iron (as Fe)	0	0.3	No Relaxation
9	Chlorides (as Cl)	8	250	1000
10	Total Hardness (as CaCO ₃)	24	200	600
11	Alkalinity (as CaCO ₃)	40	200	600
12	Permanent Hardness(As CaCO ₃)	0	-	-

- This Report is restricted only for the sample/s submitted to this laboratory.
- It is presumed that the representative sample from the source is sent for analysis.

REMARKS

✓ A) Water Sample No. ① is chemically fit/potable for drinking purposes on the basis of analyzed parameters only. However, this/these water source(s) can be used for drinking purposes only after proper disinfection and ascertaining it's bacteriological quality.

✗ B) Sample No. Contain/s is/ are more than the Desirable limit as per BIS specifications. However, it can be used for drinking purposes only in the absence of alternate source and only after proper treatment & disinfection and ascertaining it's bacteriological quality.

✗ C) Sample No. Contains /s is/are more than the Permissible limit as per BIS specifications. Hence this / these water source(s) is / are Unfit for drinking purposes.

HEALTH SERVICES

LR. No - 171 / 1293 /2025

Date: - 17.04.2025

Forwarded With Compliments To:-

Principal,
Scholar's international School,
Maregaon.
With reference to letter no. Dated 15/4/2025

llg
Chief Bacteriologist
Dist. Public Health Laboratory
Yavatmal